

Certificate Number: TUV017083EA



CERTIFICATE OF APPROVAL

Authorised marking: TUV017083EA

This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

CERTIFICATE HOLDER: Key Tubing and Electrical
6 Manufull St., Melrose Park, Adelaide
South Australia 5039
Australia

DESCRIPTION OF EQUIPMENT

Declared class: Residual Current Device

Product: Portable residual current device with overcurrent protection

Trade Name / Manufacturer: KEY RV POD / I-Sheng Electric Wire & Cable Co., Ltd.

Model Number: POD

Ratings: 220/250Va.c. 50Hz, 10A max., $I_{\Delta n} = 30\text{mA}$, $I_{cn} = 4500\text{A}$, Type A
Class L, IP55, Instantaneous tripping current: C

Standard: AS/NZS 3190: 2011

Issue Date: 18/11/2014

Expiry Date: 18/11/2019

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to be 'Johny', written over a horizontal line.



Acc. No. Z2870404AA
www.jas-anz.org/register

TUV Rheinland Australia Pty Ltd
182 Dougharty Road, Heidelberg West VIC 3081
Phone: +61 (3) 9450 1400
Email: certification@au.tuv.com
Website: www.au.tuv.com